

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Town of Farmington Consolidated Water and Sewer District
Project: Drinking Water
Sample Matrix: Drinking Water
Sample Name: 135 Hook Road
Lab Code: R2407216-001

Service Request: R2407216
Date Collected: 08/06/24 09:43
Date Received: 08/06/24 16:00

Units: ug/L
Basis: NA

Purgeable Organic Compounds by GC/MS

Analysis Method: 524.2

Analyte Name	Result	MRL	Dil.	Date Analyzed	Q
Bromodichloromethane	17	0.50	1	08/08/24 19:01	
Bromoform	ND U	0.50	1	08/08/24 19:01	
Chloroform	56 E	0.50	1	08/08/24 19:01	
Dibromochloromethane	4.1	0.50	1	08/08/24 19:01	
Trihalomethanes, Total	78	2.0	1	08/08/24 19:01	

Surrogate Name	% Rec	Control Limits	Date Analyzed	Q
1,2-Dichlorobenzene-d4	73	70 - 130	08/08/24 19:01	
Bromofluorobenzene	77	70 - 130	08/08/24 19:01	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Town of Farmington Consolidated Water and Sewer District
Project: Drinking Water
Sample Matrix: Drinking Water
Sample Name: 135 Hook Road
Lab Code: R2407216-001

Service Request: R2407216
Date Collected: 08/06/24 09:43
Date Received: 08/06/24 16:00

Units: ug/L
Basis: NA

Purgeable Organic Compounds by GC/MS

Analysis Method: 524.2

Analyte Name	Result	MRL	Dil.	Date Analyzed	Q
Bromodichloromethane	14 D	1.3	2.5	08/09/24 21:18	
Bromoform	ND U	1.3	2.5	08/09/24 21:18	
Chloroform	50 D	1.3	2.5	08/09/24 21:18	
Dibromochloromethane	3.1 D	1.3	2.5	08/09/24 21:18	
Trihalomethanes, Total	67 D	5.0	2.5	08/09/24 21:18	

Surrogate Name	% Rec	Control Limits	Date Analyzed	Q
1,2-Dichlorobenzene-d4	88	70 - 130	08/09/24 21:18	
Bromofluorobenzene	90	70 - 130	08/09/24 21:18	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Town of Farmington Consolidated Water and Sewer District
Project: Drinking Water
Sample Matrix: Drinking Water
Sample Name: 357 County Rd 28
Lab Code: R2407216-002

Service Request: R2407216
Date Collected: 08/06/24 09:26
Date Received: 08/06/24 16:00

Units: ug/L
Basis: NA

Purgeable Organic Compounds by GC/MS

Analysis Method: 524.2

Analyte Name	Result	MRL	Dil.	Date Analyzed	Q
Bromodichloromethane	18	0.50	1	08/08/24 19:26	
Bromoform	ND U	0.50	1	08/08/24 19:26	
Chloroform	64 E	0.50	1	08/08/24 19:26	
Dibromochloromethane	4.2	0.50	1	08/08/24 19:26	
Trihalomethanes, Total	86	2.0	1	08/08/24 19:26	

Surrogate Name	% Rec	Control Limits	Date Analyzed	Q
1,2-Dichlorobenzene-d4	75	70 - 130	08/08/24 19:26	
Bromofluorobenzene	78	70 - 130	08/08/24 19:26	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Town of Farmington Consolidated Water and Sewer District
Project: Drinking Water
Sample Matrix: Drinking Water
Sample Name: 357 County Rd 28
Lab Code: R2407216-002

Service Request: R2407216
Date Collected: 08/06/24 09:26
Date Received: 08/06/24 16:00

Units: ug/L
Basis: NA

Purgeable Organic Compounds by GC/MS

Analysis Method: 524.2

Analyte Name	Result	MRL	Dil.	Date Analyzed	Q
Bromodichloromethane	14 D	1.3	2.5	08/09/24 21:43	
Bromoform	ND U	1.3	2.5	08/09/24 21:43	
Chloroform	53 D	1.3	2.5	08/09/24 21:43	
Dibromochloromethane	3.4 D	1.3	2.5	08/09/24 21:43	
Trihalomethanes, Total	71 D	5.0	2.5	08/09/24 21:43	

Surrogate Name	% Rec	Control Limits	Date Analyzed	Q
1,2-Dichlorobenzene-d4	87	70 - 130	08/09/24 21:43	
Bromofluorobenzene	88	70 - 130	08/09/24 21:43	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Town of Farmington Consolidated Water and Sewer District
Project: Drinking Water
Sample Matrix: Drinking Water
Sample Name: 448 Sheldon Rd
Lab Code: R2407216-003

Service Request: R2407216
Date Collected: 08/06/24 08:48
Date Received: 08/06/24 16:00

Units: ug/L
Basis: NA

Purgeable Organic Compounds by GC/MS

Analysis Method: 524.2

Analyte Name	Result	MRL	Dil.	Date Analyzed	Q
Bromodichloromethane	17	0.50	1	08/08/24 19:51	
Bromoform	ND U	0.50	1	08/08/24 19:51	
Chloroform	57 E	0.50	1	08/08/24 19:51	
Dibromochloromethane	4.1	0.50	1	08/08/24 19:51	
Trihalomethanes, Total	77	2.0	1	08/08/24 19:51	

Surrogate Name	% Rec	Control Limits	Date Analyzed	Q
1,2-Dichlorobenzene-d4	74	70 - 130	08/08/24 19:51	
Bromofluorobenzene	80	70 - 130	08/08/24 19:51	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Town of Farmington Consolidated Water and Sewer District
Project: Drinking Water
Sample Matrix: Drinking Water
Sample Name: 448 Sheldon Rd
Lab Code: R2407216-003

Service Request: R2407216
Date Collected: 08/06/24 08:48
Date Received: 08/06/24 16:00

Units: ug/L
Basis: NA

Purgeable Organic Compounds by GC/MS

Analysis Method: 524.2

Analyte Name	Result	MRL	Dil.	Date Analyzed	Q
Bromodichloromethane	12 D	1.3	2.5	08/09/24 22:08	
Bromoform	ND U	1.3	2.5	08/09/24 22:08	
Chloroform	42 D	1.3	2.5	08/09/24 22:08	
Dibromochloromethane	2.9 D	1.3	2.5	08/09/24 22:08	
Trihalomethanes, Total	57 D	5.0	2.5	08/09/24 22:08	

Surrogate Name	% Rec	Control Limits	Date Analyzed	Q
1,2-Dichlorobenzene-d4	90	70 - 130	08/09/24 22:08	
Bromofluorobenzene	90	70 - 130	08/09/24 22:08	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Town of Farmington Consolidated Water and Sewer District
Project: Drinking Water
Sample Matrix: Drinking Water
Sample Name: 5923 Loomis Rd
Lab Code: R2407216-004

Service Request: R2407216
Date Collected: 08/06/24 08:31
Date Received: 08/06/24 16:00

Units: ug/L
Basis: NA

Purgeable Organic Compounds by GC/MS

Analysis Method: 524.2

Analyte Name	Result	MRL	Dil.	Date Analyzed	Q
Bromodichloromethane	17	0.50	1	08/08/24 20:16	
Bromoform	ND U	0.50	1	08/08/24 20:16	
Chloroform	58 E	0.50	1	08/08/24 20:16	
Dibromochloromethane	4.2	0.50	1	08/08/24 20:16	
Trihalomethanes, Total	80	2.0	1	08/08/24 20:16	

Surrogate Name	% Rec	Control Limits	Date Analyzed	Q
1,2-Dichlorobenzene-d4	85	70 - 130	08/08/24 20:16	
Bromofluorobenzene	85	70 - 130	08/08/24 20:16	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Town of Farmington Consolidated Water and Sewer District
Project: Drinking Water
Sample Matrix: Drinking Water
Sample Name: 5923 Loomis Rd
Lab Code: R2407216-004

Service Request: R2407216
Date Collected: 08/06/24 08:31
Date Received: 08/06/24 16:00

Units: ug/L
Basis: NA

Purgeable Organic Compounds by GC/MS

Analysis Method: 524.2

Analyte Name	Result	MRL	Dil.	Date Analyzed	Q
Bromodichloromethane	13 D	1.3	2.5	08/09/24 22:33	
Bromoform	ND U	1.3	2.5	08/09/24 22:33	
Chloroform	46 D	1.3	2.5	08/09/24 22:33	
Dibromochloromethane	3.2 D	1.3	2.5	08/09/24 22:33	
Trihalomethanes, Total	63 D	5.0	2.5	08/09/24 22:33	

Surrogate Name	% Rec	Control Limits	Date Analyzed	Q
1,2-Dichlorobenzene-d4	92	70 - 130	08/09/24 22:33	
Bromofluorobenzene	93	70 - 130	08/09/24 22:33	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Town of Farmington Consolidated Water and Sewer District
Project: Drinking Water
Sample Matrix: Drinking Water
Sample Name: 5150 North St
Lab Code: R2407216-005

Service Request: R2407216
Date Collected: 08/06/24 10:53
Date Received: 08/06/24 16:00

Units: ug/L
Basis: NA

Purgeable Organic Compounds by GC/MS

Analysis Method: 524.2

Analyte Name	Result	MRL	Dil.	Date Analyzed	Q
Bromodichloromethane	13	0.50	1	08/08/24 20:41	
Bromoform	ND U	0.50	1	08/08/24 20:41	
Chloroform	39	0.50	1	08/08/24 20:41	
Dibromochloromethane	3.2	0.50	1	08/08/24 20:41	
Trihalomethanes, Total	55	2.0	1	08/08/24 20:41	

Surrogate Name	% Rec	Control Limits	Date Analyzed	Q
1,2-Dichlorobenzene-d4	80	70 - 130	08/08/24 20:41	
Bromofluorobenzene	82	70 - 130	08/08/24 20:41	