

Town of Farmington Planning Board
1000 County Rd. 8
Farmington, NY 14425

November 1, 2019

RE: Project Status Log – 11-1-2019

Dear Town of Farmington Planning Board,

Delaware River Solar (“DRS”) is pleased to have the opportunity to bring the benefits of Community Solar to the Town of Farmington. DRS has proposed three (3), 2.388 Mega Watt ac Community Solar facilities that will generate, in the aggregate, approximately 7 MW of clean and “green” electricity that will be distributed over the existing electrical grid (the “Projects”).

As mentioned in our October 31, 2019 Project Status letter, the site plan has been updated based on verification by RGE of where the utility interconnection poles, and access roads to service these poles must be sited. This detail was verified on a site visit conducted by RGE on October 10, 2019, and has been updated through design revisions with DRS through October 31. As mentioned in our Project Memorandum, and at previous review meetings, each project requires their own Point of Interconnection (POI) to connect to existing RGE powerlines. From the 10/10 site visit, RGE proposed that two new access roads be built to serve two of the POI, and the center POI would be served from the originally proposed access road. Normally, POI detail is only possible to determine by RGE after a final site plan is approved for a project. In this case, RGE was able to conduct their site visit prior to final site plan approval, in part because they are required to schedule the design and ordering of the POI equipment within a certain timeframe, and because DRS requested this to be done so that full site plan details can be determined prior to SEQR being amended.

DRS has completed coordination with RGE to revise the POI design, so that all three POI locations can be sited at the central access road. This change avoids building two additional access roads from Fox Road, and also minimizes visual impacts to the greatest extent possible. These changes do not impact the SWPPP scope, so the SWPPP will be updated after comments are received by the Town Engineer. Attached with this letter are updated site plans, to be reviewed by the Planning Board, and to be circulated to SEQR Involved Agencies.

We thank the Town of Farmington for the thorough review of these projects, and look forward to the continued review of the Site Plan, Subdivision, and Special Permit applications.

Sincerely,

Daniel Compitello
Project Developer



DELAWARE RIVER SOLAR

130 North Winton Road #415
Rochester, NY 14610